

2005 EPACT ENERGY EFFICIENT HOME TAX CREDIT

Date:	April 19, 2006	Rating No.:	Example Rating
Building Name:	Example Home	Rating Org.:	Hathmore Technologies, LLC
Owner's Name:	Owner	Phone No.:	(816) 224-5550
Property Address:	Kansas City, MO	Rater's Name:	
Builder's Name:		Rater's No.:	Number 1
Weather Site:	Kansas City, MO	Rating Type:	Based On Plans
File Name:	Example Tax Credit Home.blg	Rating Date:	03/07/06

**Normalized Energy Consumption (MMBtu/year)**

	2004 IECC 50% Target	As Designed
Heating:	7.3	4.5
Cooling:	3.3	4.2
Total:	10.6	8.7

**Envelope Loads (MMBtu/year)**

	2004 IECC 90% Target	As Designed
Heating:	31.8	22.9
Cooling:	18.0	12.8
Total:	49.8	35.7

**This home MEETS the requirements for the residential energy efficiency tax credits under Section 1332, Credit for Construction of New Energy Efficient Homes, of the Energy Policy Act of 2005.**

**Building Shell Features**

Ceiling Flat: R-50  
 Vaulted Ceiling: NA  
 Above Grade Walls: R-17, R-13  
 Foundation Walls: NA  
 Exposed Floor: R-19

Slab: R-5.0 Edge, R-5.0 Under  
 Duct: Uninsulated  
 Window: U-Value = 0.360, SHGC = 0.450  
 Duel-Fuel HP: Electric/Natural gas, Htg: 7.8 HSPF. Clg: 13.0 SEER.  
 Duel-Fuel HP: Electric/Natural gas, Htg: 7.8 HSPF. Clg: 13.0 SEER.

**Under penalties of perjury, I declare that I have examined this certification, including accompanying documents, and to the best of my knowledge and belief, the facts presented in support of this certification are true, correct, and complete.**

Name: \_\_\_\_\_ Company: \_\_\_\_\_  
 Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**REM/Rate - Residential Energy Analysis and Rating Software v12.2**

This information does not constitute any warranty of energy cost or savings.  
 © 1985-2006 Architectural Energy Corporation, Boulder, Colorado.