

Tax Credit Summary Report

CLIMATE											
✓	Design Location	Tmy Site	Design Temp 97.5 % 2.5 %		Int Design Temp Winter Summer		Heating Degree Days	Design Moisture	Daily Temp Range		
—	GA, Atlanta	GA_ATLANTA	22	92	75	70	3095	34	Medium		
FLOORS											
✓	#	Floor Type	Exposed Perimeter	Wall Ins. R-Value	Area	Floor Joist R-Value	Tile	Wood	Carpet		
—	1	Crawlspace	140 ft	0	1200 ft ²	30	0.2	0	0.8		
ROOF											
✓	#	Roof Type	Materials	Attic Type	Attic Area	Roof Color	Solar Absor.	RBS	Deck Insul.	Attic Vent Ratio (1 in)	Pitch
—	1	Gable or shed	Composition shingles	Full attic	1200 ft ²	White	0.75	Y	0	300	18.4 deg
CEILING											
✓	#	Ceiling Type	R-Value	Area	Framing Frac	Truss Type					
—	1	Under Attic	38	2000 ft ²	0.11	Wood					
WALLS											
✓	#	Ornt	Adjacent To	Wall Type	R-Value	Area	Framing Fraction	Solar Absor.	Exterior Sheathing		
—	1	N	Exterior	Frame - Wood	11	360 ft ²	0.23	0.5	3		
—	2	S	Exterior	Frame - Wood	11	360 ft ²	0.23	0.5	3		
—	3	E	Exterior	Frame - Wood	11	270 ft ²	0.23	0.5	3		
—	4	W	Exterior	Frame - Wood	11	270 ft ²	0.23	0.5	3		
—	5	N	Exterior	Frame - Wood	11	360 ft ²	0.23	0.5	3		
—	6	S	Exterior	Frame - Wood	11	360 ft ²	0.23	0.5	3		
—	7	E	Exterior	Frame - Wood	11	270 ft ²	0.23	0.5	3		
—	8	W	Exterior	Frame - Wood	11	270 ft ²	0.23	0.5	3		
DOORS											
✓	#	Wall ID	Door Type	Storms		U-Value	Area				
—	1	3	Wood	None		0.2	20 ft ²				
—	2	4	Wood	None		0.2	20 ft ²				